

Delaware Department of Transportation

**QUESTIONS AND ANSWERS**

**T201303101.01**

**Community Transportation Fund, North II, 2013, Open End**

**Tuesday, February 19, 2013**

<b>Q #</b>	<b>Question</b>	<b>Answer</b>
7	For bid item 406001, if we assume the detail on page 15 of the plans is correct, showing the depth of patching at 6" so the 406001 quantity at 2000 SY-IN divided by 6" would be 333.3 SY of patching and this quantity of patching would require 112 tons of patching hot mix. Why is the bid quantity for this item 250 tons?	The Open End CTF contracts have no specific locations at the time of advertisement and the quantities are averages from previous CTF Contracts and do not directly correlate to any planned activity or location. They are items that have been used on contracts in the past and may be used on this one.
6	What is bid item 401647 used for on this project? We also need to know the depth of placement to figure the tack coat quantity.	401647 – where necessary, varies 2.25" – 3"
5	What is the depth of placement for bid item 401644? Contractor needs to know this information to figure the tack quantity which is incidental to this item?	401644 – typically 2"
4	What will items 302007 and 302008 be used for on this contract?	302007 includes under curb, under sidewalk, etc. In some cases it is incidental to another item and in some cases it is paid separately, depending on the specification. 302008 will be used in patching areas.
3	What will be the depths of bid item 708050, 708051, & 708585 in order to get material pricing?	The Open End CTF contracts have no specific locations at the time of advertisement and the quantities are averages from previous CTF Contracts and do not directly correlate to any planned activity or location. They are items that have been used on contracts in the past and may be used on this one.
2	Will bid items 701004, 701010, 701011, 701020, 701021, 701022, 705001, & 705002 all be considered remove and replacement items?	No, we have separate pay item for PCC removal.
1	Since there are no plans to this contract how does the contractor determine the depths of bid item 612020, 612021, 612022, and 612529 to determine the amount of pipe excavation and select backfill which according to DelDOT specs are incidental to all pipes under 24" in diameter?	The Open End CTF contracts have no specific locations at the time of advertisement and the quantities are averages from previous CTF Contracts and do not directly correlate to any planned activity or location. They are items that have been used on contracts in the past and may be used on this one.